


C.Q.M.

K.A.N.- Japan Corporation

CONSOLIDATED REPORT OF TOTAL SAVINGS FROM SRS INSTALLATION

CUSTOMER: **Dai Nippon Printing**
 INSTALLATION SITE: **0**
 COOLING TOWER SIZE (TR): **480**
 YEAR OF INSTALLATION: **2005**



CALCULATION OF EVAPORATION FLOW RATE ACORDING TO:			$mc_p \Delta T = E \lambda$
m - Cooling water flow in the system [Ton / hr]	304	Ton/hr	
TR - Cooling tower capacity [TR]	480	TR	
Cp - Specific heat - [Ton cal / Ton water °c]	1	Ton cal / Ton water °C	
Ti - inlet cooling water temp [°c]	22.3	°C	
To -outlet cooling water temp [°c]	18.0	°C	
?T - ?T = Ti - To	4.4		
Cooling tower conductivity without CQM	1,351	μs	
Cooling tower conductivity with CQM	4500	μs	
Makeup water conductivity μs	358	μs	
λ latent heat evaporating water temp. [Ton Cal / Ton w	540	Ton cal / Ton water °C	
E - Evaporating water [Ton / hr]	2.46	Ton/hr	

SAVINGS IN DRAINAGE FLOW RATE:			$B = E / (C-1)$
	BEF. SRS	WITH SRS	SAVINGS
B - Drainage flow rate	0.88	0.21	0.67 Ton/hr
E - Evaporation flow rate	2.46	2.46	Ton/hr
C - Concentration cycle	3.78	12.58	

CALCULATION OF SAVINGS:		
Cooling tower working hours per year	4500	hr / yr
Average utilization capacity	80%	usd / m3
Cost of one cubic water	1.42	usd / m3
Cost of chemical treatment to one cubic water	0.68	usd / m3
Water savings from drainage	3,443	usd / m3
Chemical treatment savings	18,163	usd / m3
Water savings from re-utilization	1,087	usd
TOTAL SAVINGS	22,693	usd/yr